

CUMBERLAND SCHOOL DEPARTMENT

SC-PR-11-2018-36

RESOLUTION: RESOLUTION **AUTHORIZING** AND **EMPOWERING** CUMBERLAND SCHOOL COMMITTEE TO AMEND A CONTRACT (SC-PR-4-2018-10) WITH ARDEN ENGINEERING OF PAWTUCKET, RI TO REPLACE ELECTRICAL PANEL AND MAIN SWITCH GEAR AT THE HIGH SCHOOL IN AN AMOUNT NOT TO EXCEED \$8,227.03. BE IT RESOLVED BY THE CUMBERLAND SCHOOL DEPARTMENT OF CUMBERLAND AS FOLLOWS: WHEREAS: The District during the replacement of the main switch gear and electrical panels at the High school due to being potentially a fire hazard and being obsolete it was discovered that the water mains and the cable tray at the high school were not grounded properly and caused a safety hazard. NOW THEREFORE, BE IT RESOLVED BY THE CUMBERLAND SCHOOL COMMITTEE OF THE TOWN OF CUMBERLAND, RHODE ISLAND AS FOLLOWS: **SECTION 1:** The Cumberland School Committee hereby empowers the Superintendent of Schools to execute an increase to the contract with Arden Engineering of Pawtucket, RI in an amount not to exceed one hundred fifty one thousand, twenty-seven dollars and three cents (\$151,027.03). SECTION 2: THIS RESOLUTION SHALL BECOME EFFECTIVE IMMEDIATELY UPON PASSAGE BY THE CUMBERLAND SCHOOL COMMITTEE DATE ADOPTED: 11-26-18 A TRUE COPY, ATTEST: CUMBERLAND SCHOOL COMMITTEE 11/26/2018

Town of Cumberland Fiscal Note

Description of Ordinance, Rule, or Resolution:

A RESOLUTION AUTHORIZING AND EMPOWERING THE CUMBERLAND SCHOOL COMMITTEE TO AMEND A CONTRACT WITH ARDEN ENGINEERING OF PAWTUCKET, RI FOR REPLACING ELECTRICAL PANELS AND MAIN SWITCHGEAR AT THE HIGH SCHOOL IN AMOUNT NOT TO EXCEED \$8,227.03.

Cost(s) of:

The cost shall not exceed \$8,227.03

Are said Costs/Revenue budgeted? If so, describe. If not, where shall the appropriation originate?

Said costs are in the FACILITIES REPAIR Budget

Source(s) of Data:

Sodexo Maintenance, Business Office

Bid Information:

Other Notes:

Proponent Signature:

Alex Prignano Business Manager October 24, 2018